



COMUNE DI ROSOLINI

Libero Consorzio Comunale - Siracusa

SIMULAZIONE PARAMETRI IMPIANTO

RIDUZIONE DEI CONSUMI NELL'EDIFICIO SCOLASTICO

SACRO CUORE E REALIZZAZIONE DI UN IMPIANTO

FOTOVOLTAICO A SERVIZIO DEI CONSUMI

COMUNE DI ROSOLINI

VIA DANTE ALIGHIERI, 96019, ROSOLINI (SR)



Allegati:

- *Simulazione parametri impianto.*

DATA

03/06/2019

IL TECNICO

Ing. Corrado Mingo

Geom. Gaetano Borgia

Grid-Connected System: Simulation parameters

Project : PLESSO SCOLASTICO SACRO CUORE

Geographical Site ROSOLINI CMSF

Country Italy

Situation Latitude 36.82° N Longitude 14.95° E

Time defined as Legal Time Time zone UT Altitude 151 m

Albedo 0.20

Meteo data: ROSOLINI CMSF PVGIS CM SAF, satellite 1998-2011 - Synthetic

Simulation variant : New simulation variant

Simulation date 03/06/19 14h08

Simulation parameters

Collector Plane Orientation Tilt 30°

Azimuth 0°

Models used Transposition Perez

Diffuse Perez, Meteororm

Horizon Free Horizon

Near Shadings Linear shadings

PV Array Characteristics

PV module Si-mono Model CS3K-300MS

Original PVsyst database Manufacturer Canadian Solar Inc.

Number of PV modules In series 15 modules

In parallel 6 strings

Total number of PV modules Nb. modules 90

Unit Nom. Power 300 Wp

Array global power Nominal (STC) 27.00 kWp

At operating cond. 24.52 kWp (50°C)

Array operating characteristics (50°C) U mpp 439 V

I mpp 56 A

Total area Module area 150 m²

Cell area 132 m²

Inverter

Model TRIO-8.5-TL-OUTD-400

Original PVsyst database

Manufacturer ABB

Characteristics Operating Voltage 175-950 V

Unit Nom. Power 8.50 kWac

Inverter pack Nb. of inverters 3 units

Total Power 26 kWac

PV Array loss factors

Array Soiling Losses Loss Fraction 2.0 %

Thermal Loss factor U_c (const) 20.0 W/m²K U_v (wind) 0.0 W/m²K / m/s

Wiring Ohmic Loss Global array res. 116 mOhm Loss Fraction 1.3 % at STC

LID - Light Induced Degradation Loss Fraction 1.4 %

Module Quality Loss Loss Fraction -0.5 %

Module Mismatch Losses Loss Fraction 1.0 % at MPP

Strings Mismatch loss Loss Fraction 0.10 %

Incidence effect (IAM): User defined IAM profile

10°	20°	30°	40°	50°	60°	70°	80°	90°
0.998	0.998	0.995	0.992	0.986	0.970	0.917	0.763	0.000

System loss factors

Wiring Ohmic Loss Wires: 3x10.0 mm² 49 m Loss Fraction 1.5 % at STC

Unavailability of the system 3.6 days, 3 periods Time fraction 1.0 %

User's needs : Unlimited load (grid)

Auxiliaries loss constant (fans) 100 W ... from Power thresh. 0.0 kW

Grid-Connected System: Near shading definition

Project : PLESSO SCOLASTICO SACRO CUORE

Simulation variant : New simulation variant

Main system parameters

System type **Grid-Connected**

Near Shadings

PV Field Orientation

PV modules

PV Array

Inverter

Inverter pack

User's needs

Linear shadings

tilt

30°

Model

CS3K-300MS

Nb. of modules

90

Model

TRIO-8.5-TL-OUTD-400

Nb. of units

3.0

Unlimited load (grid)

azimuth

0°

Pnom

300 Wp

Pnom total

27.00 kWp


Pnom

8.50 kW ac

Pnom total


25.50 kW ac

Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

PLESSO SCOLASTICO SACRO CUORE



Grid-Connected System: Main results

Project : PLESSO SCOLASTICO SACRO CUORE

Simulation variant : New simulation variant

Main system parameters

System type Grid-Connected

Near Shadings

Linear shadings

PV Field Orientation

tilt

30°

azimuth

0°

PV modules

Model

CS3K-300MS

Pnom

300 Wp

PV Array

Nb. of modules

90

Pnom total

27.00 kWp

Inverter

Model

TRIO-8.5-TL-OUTD-400

Pnom

8.50 kW ac

Inverter pack

Nb. of units

3.0

Pnom total

25.50 kW ac

User's needs

Unlimited load (grid)

Main simulation results

System Production

Produced Energy

45.68 MWh/year


Specific prod.

1692 kWh/kWp/year


Performance Ratio PR

78.32 %

Normalized productions (per installed kWp): Nominal power 27.00 kWp



Performance Ratio PR



New simulation variant

Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray MWh	E_Grid MWh	PR
January	79.0	32.41	11.10	120.9	110.6	2.764	2.547	0.780
February	96.3	37.57	10.90	134.2	125.1	3.131	2.998	0.827
March	152.2	60.88	12.60	185.8	173.6	4.283	4.101	0.818
April	180.9	59.70	15.70	195.1	182.1	4.417	4.228	0.802
May	225.4	67.61	19.20	220.3	205.6	4.906	4.686	0.788
June	242.1	55.68	23.50	224.4	209.9	4.909	4.690	0.774
July	254.8	48.42	26.80	241.3	226.8	5.190	4.956	0.761
August	224.1	49.31	26.90	234.3	220.3	5.046	4.608	0.729
September	161.1	51.55	24.00	189.3	177.3	4.164	3.983	0.779
October	125.2	50.10	20.30	166.3	155.3	3.733	3.573	0.796
November	86.4	33.70	16.30	131.8	121.1	2.977	2.791	0.785
December	71.9	28.77	12.30	116.6	105.2	2.637	2.521	0.801
Year	1899.6	575.69	18.34	2160.3	2012.8	48.156	45.683	0.783

Legends: GlobHor

Horizontal global irradiation

DiffHor

Horizontal diffuse irradiation

T Amb

Ambient Temperature

GlobInc

Global incident in coll. plane

GlobEff

Effective Global, corr. for IAM and shadings

EArray

Effective energy at the output of the array

E_Grid

Energy injected into grid

PR

Performance Ratio

Grid-Connected System: Loss diagram

Project : PLESSO SCOLASTICO SACRO CUORE

Simulation variant : New simulation variant

Main system parameters	System type	Grid-Connected		
Near Shadings	Linear shadings			
PV Field Orientation	tilt	30°	azimuth	0°
PV modules	Model	CS3K-300MS	Pnom	300 Wp
PV Array	Nb. of modules	90	Pnom total	27.00 kWp
Inverter	Model	TRIO-8.5-TL-OUTD-400	Pnom	8.50 kW ac
Inverter pack	Nb. of units	3.0	Pnom total	25.50 kW ac
User's needs	Unlimited load (grid)			

Loss diagram over the whole year

